

AMiNi4DW2/G

Compact control system with Ethernet interface

Operation manual

Version 1.03



AMiT, spol. s r. o. does not provide any warranty concerning the contents of this publication and reserves the right to change the documentation without any obligation to inform about it.

This document can be copied and redistributed under following conditions:

1. The whole text (all pages) must be copied without any changes.
2. All redistributed copies must retain the AMiT, spol. s r. o. copyright notice and any other notices contained in the documentation.
3. This document must not be distributed for purpose making of profit.

The names of products and companies used herein can be trademarks or registered trademarks of their respective owners.

AMiT is a registered trademark.

**Copyright (c) 2014, AMiT, spol. s r. o.
Producer: AMiT, spol. s r. o.
Naskové 1100/3, 150 00 Praha
www.amit.cz**

Technical support: support@amit.cz

Contents

	History of revisions	4
	Related documentation.....	4
1.	Introduction	5
2.	Technical parameters	6
2.1.	Dimensions.....	10
2.2.	Recommended drawing symbol	11
3.	Conformity assessment	12
3.1.	Other tests	13
4.	Power supply.....	14
5.	Inputs/outputs	16
5.1.	Digital inputs.....	16
5.2.	Digital outputs.....	19
5.3.	Analogue inputs.....	21
5.4.	Analogue outputs.....	25
6.	Communication lines.....	27
6.1.	RS485	27
6.1.1	RS485 line termination	28
6.2.	Ethernet.....	29
6.3.	GSM modem	30
7.	Internal measuring, SD card	32
7.1.	Backup battery measurement.....	32
7.2.	Measuring of power supply voltage	32
7.3.	SD card	32
8.	System LEDs and CFG switches.....	34
9.	Configuration	35
9.1.	HW configuration	35
9.2.	SW configuration	35
9.3.	Factory setting, jumpers	36
9.4.	Restoring the factory setting.....	37
10.	Mounting	38
10.1.	Installation rules.....	38
11.	Ordering information and completion	40
11.1.	Completion	40
12.	Maintenance	41
13.	Waste disposal.....	42

History of revisions

Document name: amini4dw2g_g_en_103.pdf

Author: Zbyněk Říha

Revision	Date	Changes
100	25. 10. 2013	New document
101	18. 11. 2013	Information addition about analog inputs accuracy
102	02. 07. 2014	Chapters 2., 3., 4., 6.1., 7.3. revision, pictures revision
103	24. 07. 2014	Chapter 3. revision

Related documentation

1. DetStudio Development Environment Help
2. Application Note AP0016 – Principles of using RS485 interface
file: ap0016_en_xx.pdf
3. Application Note AP0017 – Counter inputs, counting of revolutions/pulses
file: ap0017_en_xx.pdf
4. Application Note AP0033 – Alternative using of analogue inputs
file: ap0033_en_xx.pdf
5. Application Note AP0037 – Principles of using Ethernet network
file: ap0037_en_xx.pdf
6. Application Note AP0046 – Setting web server
file: ap0046_en_xx.pdf
7. Application Note AP0050 – Project documentation for AMiT company products
file: ap0050_en_xx.pdf

1. Introduction

AMiNi4DW2/G is a small, compact control system built in plastic box.

- Basic features**
- Graphic black & white LCD display (122 × 32) pixels
 - 8 buttons
 - 8 galvanically separated digital inputs
 - 8 galvanically separated digital outputs
 - 8 analogue inputs U / I / Ni1000 / Pt1000
 - 4 analogue outputs 0 V to 10 V
 - Internal GSM modem
 - RS485 serial interface with galvanic separation
 - Ethernet 10/100 Mbps interface
 - Integrated web server
 - Slot for SD card
 - DIN 35 mm rail mounting

2. Technical parameters

CPU	Procedural / Communication	ST10F269 / STM32F207
	FLASH memory	256 KB + 2048 KB
	RAM	1024 KB
	EEPROM	2 KB
	RAM + RTC back-up	Panasonic BR2477/CHCE Lithium battery
	Battery lifetime	5 years

RTC	Type	RTC72423A
	Precision at 25 °C	±20 ppm
	Precision 0 °C to 50 °C	-40 ppm to +20 ppm

Display, keyboard	Display	Graphic (122 × 32) pixels
	Backlight	Green LED
	Keyboard	8 buttons
	Buttons lifetime	10 ⁶ touches

SD card	Type	Micro SD (HC)
	Capacity	128 MB to 16 GB *)

Note: *) Micro SD card is not part of delivery.

Digital inputs	Quantity	8
	Configuration	1 × 8
	Common pole	Minus
	Type of input	24 V DC / 24 V AC
	Logical 0	Min. -30 V, max. 5 V
	Logical 1	Min. 16 V, max. 30 V
	Input current	11 mA at 24 V DC
	Input peak current	Max. 16 mA at 30 V DC
	Maximum frequency	60 kHz at 10 % duty cycle distortion 160 kHz at 30 % duty cycle distortion
	Galvanic separation	Yes, common with DO
	Insulation strength	300 V AC /1 minute *)
	Connection points	WAGO 231-309/102-000 connector
	Wire cross section	0.08 mm ² to 2.5 mm ²

Note: *) Insulation must not be used for dangerous voltage separation.

Digital outputs	Number of outputs	8
	Configuration	1 × 8
	Common wire	Minus
	Switching element	MOS
	Switched voltage	19.2 V DC to 28.8 V DC
	Switched current	300 mA
	Protection current maximum	Typically 1.5 A
	Residual current at Log. 0	0 mA
	Switch-on time	40 μs
	Switch-off time	100 μs
	Shortcut protection	Electronic
	Inductive load protection	Electronic

Galvanic separation	Yes, common with DI
Insulation strength	300 V AC /1 minute *)
Connection points	WAGO 231-309/102-000 connector
Wire cross section	0.08 mm ² to 2.5 mm ²

Note: *) Insulation must not be used for dangerous voltage separation.

Analogue inputs

Number of inputs	8
Configuration	1 × 8
Common wire	Minus
Type of inputs	0 V to 5 V / 0 V to 10 V / 0 mA to 20 mA / / Ni1000 / Pt1000 / / 24 V digital input
Resolution	10 bit
Galvanic separation	No
Connection points	WAGO 231-305/102-000 connector WAGO 231-304/102-000 connector
Wire cross section	0.08 mm ² to 2.5 mm ²

Caution: AGND (24) terminal is internally connected with GDN (33) terminal of system power supply connector.

Input range 0 V to 5 V DC

AD converter resolution (LSB)	5 mV
Accuracy	0.1 % *)
Temperature dependence	25 ppm/°C
Input DC resistance	Minimum 1 MΩ
Input circuit time constant	1 ms
Input overvoltage protection	Diodes
Maximum input voltage	50 V DC permanently

Input range 0 V to 10 V DC

AD converter resolution (LSB)	10 mV
Accuracy	0.2 % *)
Temperature dependence	35 ppm/°C
Input resistance	20 kΩ
Input circuit time constant	0.5 ms
Input overvoltage protection	Diodes
Maximum input voltage	50 V DC permanently

Input range 0 mA to 20 mA

AD converter resolution (LSB)	20 μA
Accuracy	0.2 % *)
Temperature dependence	75 ppm/°C
Input resistance	249 Ω/0.1 %
Input circuit time constant	1 ms
Input overvoltage protection	Diodes
Maximum input current	30 mA DC **)

Note: *) Measurement accuracy may be reduced by 15 % during electromagnetic interference, see chapter 3.

**) At input voltage higher than 7.5 V (input current higher than 30 mA DC) thermal overload of sensing resistor occurs.

Ni1000 input

Measuring range	-50 °C to 150 °C
Ni1000 sensor constant	6180 ppm/°C
AD converter resolution (LSB)	0.3 °C *)
Accuracy (range Ni1000. Depends on measured value. Interpolation needs to be performed)	T = -50 °C 0.8 °C **) T = 0 °C 0.9 °C **) T = 150 °C 1.2 °C **)
Input temperature dependence	75 ppm/°C
Input circuit time constant	1 ms
Input overvoltage protection	Diodes ***)

- Note: *) While NOS operating system is used.
 **) Measurement accuracy may be reduced by 15 % during electromagnetic interference, see chapter 3.
 ***) Only a resistive sensor can be connected to this input. According to technical design, when sensor is not connected, voltage of 12 V occurs on Alx input – voltage is switched on for 10 ms in 110 ms interval, common voltmeter will show average value.

Pt1000 input

Measured temperature range	-50 °C to 250 °C
Pt1000 sensor constant	3900 ppm/°C
AD converter resolution (LSB)	1 °C *)
Accuracy	T = -50 °C 1.0 °C **) T = 0 °C 1.3 °C **) T = 250 °C 2.6 °C **)
Input temperature dependence	75 ppm/°C
Input circuit time constant	1 ms
Input overvoltage protection	Diodes ***)

- Note: *) While NOS operating system is used.
 **) Measurement accuracy may be reduced by 15 % during electromagnetic interference, see chapter 3.
 ***) Only a resistive sensor can be connected to this input. According to technical design, when sensor is not connected, voltage of 12 V occurs on Alx input – voltage is switched on for 10 ms in 110 ms interval, common voltmeter will show average value.

Digital input 24 V

Logical 0	Min. -30 V, max. 5 V
Logical 1	Min. 8 V, max. 30 V
Input current	2 mA at 24 V DC
Input peak current	Max. 3 mA at 30 V DC
Input overvoltage protection	Diodes
Maximum frequency	100 Hz at 10 % duty cycle distortion 500 Hz at 30 % duty cycle distortion
Galvanic separation	No
Maximum input voltage	50 V DC permanently

Analogue outputs

Number of outputs	4
Configuration	1 × 4
Common wire	Minus

Output range	0 V to 10 V
Minimum load	1 k Ω
Maximum capacitive load	10 nF
Maximum output current	10 mA
Adjustment error	0.2 %
Resolution	10 bit
Resolution per 1 bit	10 mV
Transition time 0 V to 10 V DC, accuracy 1 %	Maximum 25 ms
Residual ripple	20 mV
Temperature dependence	35 ppm/ $^{\circ}$ C
Maximum wire length	100 m
Output circuitry protection	Transil 600 W
Galvanic separation	No
Connection points	WAGO 231-305/102-000 connector
Wire cross section	0.08 mm ² to 2.5 mm ²

Caution: AGND (1) terminal is internally connected with GDN (33) terminal of system power supply.

Presented parameters are valid while NOS operating system is used.

GSM	GSM bands	850 MHz, 900 MHz, 1800 MHz, 1900 MHz
	Modem type	TELIT GL865-DUAL V3
	SIM card type	Mini (2FF)
	Antenna connection *)	SMA connector

Note: *) Antenna is not included.

RS485	Overvoltage protection	Transil 600 W
	Terminating resistor **)	120 Ω on control system
	Idle state definition **)	
	up to +5 V	1 K Ω on control system
	up to 0 V	1 K Ω on control system
	Maximum wire length	1200 m / 19200 bps
	Maximum stations count	32
	Operation indication	LED on panel
	Galvanic separation	Yes
	Insulation strength	300 V AC / 1 minute *)
Connection point	WAGO 231-303/102-000 connector	
Wire cross section	0.08 mm ² to 2.5 mm ²	

Note: *) Insulation must not be used for dangerous voltage separation.

**) Terminating resistor and idle state definition are connected together.

Ethernet	Data transmission rate	10/100 Mbps
	Interface controller used	STM32F207 + LAN8720
	Operation indication	LED on panel
	Galvanic separation	Yes
	Insulation strength	300 V AC / 1 minute *)
	Connection point	RJ45 connector, according to IEEE802.3

Note: *) Insulation must not be used for dangerous voltage separation.

Power supply	Nominal power supply voltage	24 V DC
	Power supply voltage range	19.2 V DC to 28.8 V DC
	Power consumption	Max. 200 mA at 24 V DC
	Connection point	WAGO 231-302/102-000 connector
	Wire cross section	0.75 mm ² to 2.5 mm ²
Mechanics	Mechanical design	Plastic box
	Mounting	DIN 35 mm rail mounting
	Ingress protection rate	IP20
	Weight – netto – brutto	0.46 kg ± 5 % 0.56 kg ± 5 %
	Dimensions (w × h × d)	(160 × 95 × 74) mm
Temperatures	Operating temperature	0 °C to 50 °C
	Storage temperature	-20 °C to 70 °C
Others	Maximum ambient humidity	< 95 % non-condensing
	Programming	DetStudio (NOS)

2.1. Dimensions




Fig. 1 - AMiNi4DW2/G dimensions

2.2. Recommended drawing symbol

Following drawing symbol is recommended for **AMiNi4DW2/G** control system. Only part of it will be visible in following examples.




Fig. 2 - Recommended drawing symbol for **AMiNi4DW2/G**

3. Conformity assessment

The equipment meets the requirements of NV616/2006 Czech governmental decree. The compliance assessment has been performed in accordance with harmonized standard EN 61326.

Tested in accordance with standard	Type of test	Class
EN 55011:2009	Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement	Complies, A *)
EN 61000-4-2:2009	Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test	8 kV
EN 61000-4-3:2006	Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test	Complies **)
EN 61000-4-4:2012	Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test, power supply	±4 kV
EN 61000-4-4:2012	Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test, input	±2 kV
EN 61000-4-5:2006	Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Electrostatic discharge immunity test, power supply.	±2 kV
EN 61000-4-5:2006	Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test, RS485, Ethernet	±2 kV #)
EN 61000-4-5:2006	Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test, other	±1 kV #)
EN 61000-4-6:2009	Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields	10 V **)

*) This is device of Class A. In the internal environment this product can cause some radio disturbances. In such case the user may be asked to take the appropriate measures.

**) During interference, measurement accuracy on analogue inputs is reduced.

#) Other than power supply circuitry cabling, which is longer than 30 m must be carried out by using the shielded cables.

3.1. Other tests

Tested in accordance with standard	Type of test	Classification
EN 60068-2-1:2007	Environmental testing – Part 2-1: Tests – Test A: Cold	Complies
EN 60068-2-2:2007	Environmental testing – Part 2-2: Tests – Test B: Dry heat	Complies
EN 61000-4-29:2000	Electromagnetic compatibility (EMC) – Part 4-29: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations on d.c. input power port immunity tests	Complies

4. Power supply

AMiNi4DW2/G control system can be powered only by DC power supply. Power source must meet the requirements stated in chapter 2. Technical parameters.




Fig. 3 - Power supply connector location

Legend

Number	Meaning
1	Power supply connector

Connectors numbering

Terminal	Label	Meaning
33	GND	Power supply GND
34	+24V	Power supply +24 V DC

Wiring example




Fig. 4 - Wiring example of single control system

Legend

Number	Meaning
1	External power supply 24 V DC

Note: It is recommended to connect the GND, AGND and EGND terminals with switchboard PE terminal when installation is made.

5. Inputs/outputs

5.1. Digital inputs

Digital inputs of **AMiNi4DW2/G** control system can be used for AC as well as for DC signal. The way of evaluating is determined by software.




Fig. 5 - Inputs DI0.0 to DI0.7 connector location

Legend	Number	Meaning
	1	Inputs DI0.0 to DI0.7 connector




Fig. 6 - Wiring scheme of single digital input channel

- Counter inputs** Digital counter inputs can be used on two different ways:
- INT program counter
 - Program counter

INT program counter Each digital input of the system can generate hardware interruption. These inputs can be programmed as counters through Interrupt_x processes.

Limitation of input signal frequency is given by program. It can be used typically up to 10 kHz frequency.

Program counter Each digital input can be operated by program in Hi_x processes. These inputs can be programmed as counters. Limitation of input signal frequency is given by program. It can be used typically up to 250 Hz frequency.

Other information about counter inputs can be found in Application Note AP0017 – Counter inputs, counting of revolutions/pulses.

Connectors numbering

Terminal	Label	Meaning
6	EGND	Ground terminal
7	DI0.0	Digital input 0
8	DI0.1	Digital input 1
9	DI0.2	Digital input 2
10	DI0.3	Digital input 3
11	DI0.4	Digital input 4
12	DI0.5	Digital input 5
13	DI0.6	Digital input 6
14	DI0.7	Digital input 7

Wiring examples




Fig. 7 - Passive contact supplied from individual power supply

Legend

Number	Meaning
1	External power supply 24 V DC




Fig. 8 - Connecting self-supplied active output

Legend

Number	Meaning
1	Sensor with self-supplied active output




Fig. 9 - Passive contact supplied from AC power supply

Legend

Number	Meaning
1	External power supply 24 V AC

Note: It is recommended to connect the GND and EGND terminals with switchboard PE terminal when installation is made.

5.2. Digital outputs

Semiconductor outputs are implemented as galvanically separated MOS switches 24 V/300 mA DC. Output is shortcut-protected, overheating-proof and protected against overvoltage upon switching an inductive load.




Fig. 10 - Outputs DO0.0 to DO0.7 connector location

Legend	Number	Meaning
	1	Outputs DO0.0 to DO0.7 connector

Connectors numbering	Terminal	Label	Meaning
	15	E+24V	Supplying of outputs
	16	DO0.0	Digital output 0
	17	DO0.1	Digital output 1
	18	DO0.2	Digital output 2
	19	DO0.3	Digital output 3
	20	DO0.4	Digital output 4
	21	DO0.5	Digital output 5
	22	DO0.6	Digital output 6
	23	DO0.7	Digital output 7

Note: Digital input ground terminal 6 (EGND) should be used as a digital output ground terminal (it is common for digital inputs and outputs).

Wiring example




Fig. 11 - Operating the power contactor by semiconductor output

Legend	Number	Meaning
	1	External power supply 24 V DC

Note: It is necessary to wire terminals E+24V as well as EGND, otherwise the outputs will not work properly.

It is recommended to connect the GND and EGND terminals with switchboard PE terminal when installation is made.

5.3. Analogue inputs

AMiNi4DW2/G control system has eight built-in analogue input channels. All inputs can be independently configured for ranges 0 V to 5 V / 0 V to 10 V / 0 mA to 20 mA or for direct connection of Ni1000 / Pt1000 sensors.

The analogue inputs can be also utilized as digital inputs. The way of signal evaluating is determined by software.




Fig. 12 - Inputs AI0.0 to AI0.7 connectors location

Legend	Number	Meaning
	1	Inputs AI0.4 to AI0.7 connector
	2	Inputs AI0.0 to AI0.3 connector

Connectors numbering	Terminal	Label	Meaning
	24	AGND	Analogue ground
	25	AI0.0	Analogue input 0
	26	AI0.1	Analogue input 1
	27	AI0.2	Analogue input 2
	28	AI0.3	Analogue input 3
	29	AI0.4	Analogue input 4
	30	AI0.5	Analogue input 5
	31	AI0.6	Analogue input 6
	32	AI0.7	Analogue input 7




Fig. 13 - Wiring scheme of analogue input single channel

0 V to 5 V




Fig. 14 - Setting configuration jumpers for range 0 V to 5 V

0 V to 10 V




Fig. 15 - Setting configuration jumpers for 0 V to 10 V range, digital input 24 V

0 mA to 20 mA




Fig. 16 - Setting configuration jumpers for 0 mA to 20 mA range

**Ni1000
Pt1000**




Fig. 17 - Setting configuration jumpers for Ni1000 / Pt1000 sensors

Jumpers location Configuration jumpers are accessible without cover dismounting.




Fig. 18 - Configuration jumpers location

Legend	Number	Meaning
	1	Configuration jumpers for inputs AI0.4 to AI0.7
	2	Configuration jumpers for inputs AI0.0 to AI0.3

Wiring examples




Fig. 19 - Connecting voltage sensor 0 V to 5 V

Legend	Number	Meaning
	1	Voltage sensor with 0 V to 5 V output




Fig. 20 - Connecting voltage sensor 0 V to 10 V

Legend

Number	Meaning
1	Voltage sensor with 0 V to 10 V output




Fig. 21 - Connecting sensor with current output 0 mA to 20 mA (4 mA to 20 mA)

Legend

Number	Meaning
1	Current sensor with 0 mA to 20 mA (4 mA to 20 mA) output
2	Power supply 24 V DC




Fig. 22 - Connecting Ni1000 sensor

Reference voltage supply The +5.0 V DC reference voltage is located on control system I/O board. By manufacturer is set the reference voltage with 1 mV precision. The setting trimmer is secured by colour drop.

Note: Details about shield wiring and overvoltage protection are presented in Application Note – AP0050 – Project documentation for AMiT company products.

5.4. Analogue outputs

AMiNi4DW2/G control system has four voltage analogue outputs. Output range is 0 V to 10 V. Outputs control is internally realized on the PWM basis.




Fig. 23 - Outputs AO0.0 to AO0.3 connector location

Legend	Number	Meaning
	1	Outputs AO0.0 to AO0.3 connector

Connectors numbering

Terminal	Label	Meaning
1	AGND	Analogue ground
2	AO0.0	Analogue output 0
3	AO0.1	Analogue output 1
4	AO0.2	Analogue output 2
5	AO0.3	Analogue output 3

Wiring scheme




Fig. 24 - Wiring scheme of final stage of single channel analogue output

Wiring examples




Fig. 25 - Connecting AC supplied servo

Legend

Number	Meaning
1	AC power supply

6. Communication lines

AMiNi4DW2/G control system is equipped with three communication interfaces.

- RS485 interface
- Ethernet interface
- GSM modem

6.1. RS485

RS485 is a Half-duplex serial interface, which is led out to WAGO connector. Interface can be also used for interconnecting of more stations (up to 32 on one segment) All stations communicate through single signal pair. RS485 has a number 1 within SW, in case of using NOS.




Fig. 26 - RS485 connector and indication LEDs location

Legend	Number	Meaning
	1	RS485 line LED indicators
	2	Jumpers for idle state definition and RS485 line termination
	3	RS485 line connector

Connector numbering	Terminal	Label	Meaning
	35	G485	RS485 line ground
	36	B	RS485 line, signal B
	37	A	RS485 line, signal A

Activity of RS485 line is indicated by LEDs located on front panel.

RS485 indication LEDs	LED	Meaning
	Rx485	Lights when receiving data
	Tx485	Lights when sending data

6.1.1 RS485 line termination

Two configuration jumpers which are used for line termination and idle state definition are located near RS485 interface. Both jumpers must be set at end-station (idle state definition and line termination is connected).




Fig. 27 - Connected jumpers on end station

<i>Legend</i>	Number	Meaning
	1	Connected jumpers for idle state definition and RS485 line termination

Both jumpers must be disconnected at intermediate stations (idle state definition and line termination is disconnected).




Fig. 28 - Disconnected jumpers on end station

<i>Legend</i>	Number	Meaning
	1	Disconnected jumpers for idle state definition and RS485 line termination

<i>Meaning of jumpers</i>	Jumpers	Meaning
	Are set	End-station – Idle state and line termination is active
	Are not set	Intermediate station – Idle state and line termination is inactive

More information about using the RS485 line can be found in Application Note – AP0016 – Principles of using RS485 interface.

6.2. Ethernet

Through Ethernet interface the system can be directly connected into computer LAN network, and is led out to RJ45 connector. For connecting it is possible to use components of standard structured cabling.

Ethernet interface can be used for visualization as well as for control system remote application loading. TCP/IP protocols family is used for communication, therefore the communication network can be shared both by control systems and personal computers.

The **AMiNi4DW2/G** control system can be utilized as bridge to RS485 network with DB-Net protocol.




Fig. 29 - Ethernet connector and indication LEDs location

Legend	Number	Meaning
	1	Ethernet line LED indicators
	2	Ethernet line connector

Activity on Ethernet line is indicated by system LEDs located on front panel.

RS485 indication LEDs	LED	Meaning
	LNK/ACT	Lights when connected to network, blinks when sending / receiving data
	Speed	Lights in 100 Mbps network, does not light in 10 Mbps network

Details about Ethernet interface can be found in Application Note – AP0037 – Principles of using Ethernet.

6.3. GSM modem

SMS messages can be sent/received to/from control system in UPD mode via integrated modem. Within SW the GSM port has number 2, in case of using NOS.

Antenna (not included) can be connected to control system via SMA connector on the bottom of the control system. Slot for SIM card is located behind analogue input connector AI4 to AI7, close to antenna connector.




Fig. 30 - Antenna connector and slot for SIM card location

Legend

Number	Meaning
1	SMA connector for antenna connection
2	SIM card slot

SIM card must be inserted with contacts towards the base board (board with WAGO connectors) of **AMiNi4DW2/G**. Inserting / removing the SIM card must be performed only with control system power supply turned OFF!

GSM interface activity is indicated by Rx232 and Tx232 LEDs, located on front panel.

RS232 LED indicators

LED	Meaning
Rx232	Lights when receiving data
Tx232	Lights when sending data




Fig. 31 - LED indicators location

Legend

Number	Meaning
1	LED indicators for GSM communication

7. Internal measuring, SD card

7.1. Backup battery measurement

Voltage of backup battery can be measured in applications, written in DetStudio development tool via predefined analogue channel.

Operation example AnIn #Vbatt, fBat, 5.000, 0.000, 10.000, 0.000, 10.000

Measured value is battery voltage [V].

Warning that it is time to replace the battery can be displayed in application.

7.2. Measuring of power supply voltage

Value of power supply voltage can be measured in applications, written in DetStudio development tool via predefined analogue channel.

Operation example AnIn #Vint, fPwr, 56.0000, 0.000, 56.000, 0.700, 55.000

Measured value is power supply voltage [V].

7.3. SD card

Micro SD card slot is located on the bottom of **AMiNi4DW2/G** (behind the RS485 interface connector). The way the card is used depends on used operation system and communication process program. Details about card usage are described in application software documentation.




Fig. 32 - Micro SD card slot location

Legend	Number	Meaning
	1	Micro SD card slot

Card is inserted contacts up (towards **AMiNi4DW2/G** display). Inserting / removing an SD card is not subject to the connected / disconnected power supply. Card can be freely manipulated during system run, without danger of data loss or corruption.

Caution: If the Micro SD card capacity is up to 2 GB, the FAT16 has to be used. Over 2 GB the FAT32 has to be used.

8. System LEDs and CFG switches




Fig. 33 - DIP switch and status indicator locations

Legend	Number	Meaning
	1	System LEDs
	2	CFG switches

System LEDs	LED	Colour	Meaning
	PWR	Green	Power supply is attached
	RUN	Green	Run of SW equipment Blinks with 0.5 s period – NOS operation system run Blinks with 1 s period – application run
	ERR	Red	SW equipment error Lights – SW error
	S0	Green	Procedural processor activity
	S1	Green	Procedural processor activity
	S2	Green	Procedural processor activity
	S3	Green	Communication processor activity

CFG switches	Switch	Position	Meaning
	1	ON	Setting factory defaults of communication parameters
		OFF	Standard run
	2	ON	Switching to special mode for loading NOS
		OFF	Standard run

9. Configuration

9.1. HW configuration

HW configuration is done for analogue inputs and RS485 interface via configuration jumpers, described in previous chapters. Position of all configuration jumpers is apparent from the following figure.




Fig. 34 - Configuration jumpers location

Legend	Number	Meaning
	1	RS485 configuration jumpers
	2	Configuration jumpers for inputs AI0.4 to AI0.7
	3	Configuration jumpers for inputs AI0.0 to AI0.3

9.2. SW configuration

AMiNi4DW2/G control system is not equipped with SW configuration switch. SW configuration is performed by keyboard and LCD.

After NOS operating system is loaded, SW configuration can be started by holding **ENTER** during switching power supply ON.



Fig. 35 - Configuration menu

Menu item can be selected with up and down arrows, value can be changed with left and right arrows.

Settable parameters:

- System address in DB-Net network (0 to 31)
- DB-Net communication speed (9600 / 19200 / 38400 / 115200)
- DB-Net communication interface (RS232 / RS485)
- Application (run / block)
- Service mode (according to settings / force)
- Repeatedly button pressing (off / slow / fast)

After pressing **ENTER**- dialog window for saving is displayed, pressing **ESC** will exit configuration menu without saving changes.



```

Uložit nastavení?
Potvrďte klávesou ↵
  
```

Fig. 36 - Dialog window for saving

9.3. Factory setting, jumpers

Analogue inputs All analogue inputs are set for range of 0 V to 10 V.

RS 485 configuration Jumpers, which activates line termination and idle state definition are fitted.

Ethernet	Parameter	Default value
	Station IP address	192.168.1.1
	Network mask	255.255.255.0
	Default gateway	0.0.0.0

Web server	Parameter	Default value
	Administrator login/pass	root/amit
	Service login/pass	service/amit
	User login/pass	user/amit

Parameter	Default value
FTP server – data	20
FTP server – control	21
WEB server	80

DB-Net/IP servers	Parameter	Default value
	UDP Port	59
	Password	0

9.4. Restoring the factory setting

User can use this option in case of problems in communication with control system, for example, in case of control system with unknown IP address, problems in communication over Ethernet, etc.

To restore factory settings- turn OFF power supply, put HW configuration DIP switch n. 1 to position ON (see Fig. 33), turn power supply ON. It is necessary to wait, in this state, until the LED S3 is permanently lit for minimum of 15 s. Then disconnect power supply, switch the DIP switch n. 1 backwards to position OFF, and reconnect power supply. S3 LED will blink with cca 1 s. period. Factory settings are restored.

10. Mounting

AMiNi4DW2/G control system is intended for DIN 35 mm rail mounting. Control system can be mounted in horizontal and vertical position.

10.1. Installation rules

EMC filter EMC filter is used on power supply input. Based on environment nature, power source properties and wiring layout this requirement can be revised.

Connecting to PE Connect the negative supplying terminal of control system (GND) to the switchboard PE terminal.

Digital I/O Connect the negative terminal of all inputs and outputs to the switchboard PE terminal.

The separate supplying section is recommended. Common section for digital inputs and outputs is convenient as well.

Accomplish the connection with PE on the switchboard inlet.

Use the shielded wires for longer distance lead wires and in higher level disturbance environment. Connect the shielding to the PE terminal just on switchboard input.

If the wires are led outside the building, the appropriate inputs and outputs needs to be overvoltage protected.

Analogue inputs Use the shielded signal cables for wiring. Connect the cable shielding to the PE terminal just on switchboard input.

If the wires are led outside the building, the appropriate inputs and outputs needs to be overvoltage protected.

Analogue outputs When connecting the power source for analogue drives, be particular that power circuit does not close itself through control system analogue ground.

Use the shielded signal cables for wiring. Connect the cable shielding to the PE terminal just on switchboard input.

If the wires are led outside the building, the appropriate inputs and outputs needs to be overvoltage protected.

RS485 channel It is necessary to perform connecting of RS485 line according to recommendations presented in Application Note – AP0016 – *Principles of using RS485 interface*.

Ethernet interface Unshielded – patch cable can be used for service or when utilized within the switchboard frame.

In case of permanent use outside the switchboard frame, it is necessary to perform connecting of Ethernet line according to recommendations presented in Application Note – *AP0037 – Principles of using Ethernet network*.

Note: All connections to PE terminal must be realized with as low as possible impedance. Technical parameters of unit are guaranteed only when these wiring rules are applied.

11. Ordering information and completion

Control system	AMiNi4DW2/G	Complete, see the chapter 11.1. Completion
Others	GSM-ANT-U1S	Thin-rod angle antenna, 1 dB, without cable, SMA connector
	GSM-ANT-M5S	Magnetic antenna, 5 dB, 3 m cable, SMA connector
	GSM-ANT-L2S	Self-adhesive antenna, 2.5 dB, 3 m cable, SMA connector

11.1. Completion

AMiNi4DW2/G	Part	Quantity
	Control system	1
	WAGO 231-309/102-000	2
	WAGO 231-305/102-000	2
	WAGO 231-304/102-000	1
	WAGO 231-303/102-000	1
	WAGO 231-302/102-000	1
	Operation manual	1

12. Maintenance

The control system does not require any regular inspection or service, except checking of reference voltage setting as well as voltage of backup accumulator.

Reference voltage source The reference voltage 5.0 V DC for A/D converter is set by manufacturer with 1 mV precision. For voltage inspection should be used a sufficiently precise measuring instrument!

Inspection must be carried out once every five years.

Backup battery For program and parameters backup in the RAM memory the backup battery is used. Its nominal voltage is 3.0 V DC; nominal capacity is 1 Ah. If battery voltage drops under 2.7 V DC, then it is considered to be discharged. When it happens, it is necessary to change it.

Inspection must be carried out once every five years.

With reference to manufacturer, the assumed battery lifetime is 10 years.

Cleaning Time after time with regard to way of device usage, it is necessary to remove dust from inside electronics. The equipment can be cleaned by dry soft brush or vacuum cleaner, only when turned-off and disassembled.

Note: The maintenance mentioned above can be performed by manufacturer or authorized service only!

13. Waste disposal

Electronics disposal The disposal of electronic equipment is subject to the regulations on handling electrical waste. The equipment must not be disposed off in common public waste. It must be delivered to places specified for that purpose and recycled.

Battery disposal The equipment contains a lithium battery. The battery is a dangerous waste. Therefore, it must be delivered to places specified for that purpose. Disposal of worn-out batteries and accumulators must not be in contrary to valid regulations.